

C E R T I F I C A T E
of Conformity



Registration No.: AK 50419826 0001

Report No.: 50186674 002

Holder: KEHUA FRANCE SAS
3 Place Général de Gaulle
13001 Marseille
France

Product: PV-Inverter
(Photovoltaic grid-connected inverter)

Identification:

Type Designation : KF-SPI30K-B KF-SPI33K-B KF-SPI36K-B
KF-SPI40K-B KF-SPI50K-B KF-SPI60K-B

Serial Number : 1#

Firmware Version : HMI: V2, DSP1: V2, DSP2: V2

Remark : The reference standards
refere to test report 50186674 002
for details.

Tested acc. to: UTE C15-712-1/07.13
DIN VDE V 0126-1-1/08.13
Enedis-NOI-RES_13E

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 09.10.2018



Weichun Li
Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Certificat de conformité

Fabricant : KEHUA FRANCE SAS
3 Place Général de Gaulle 13001 Marseille France

Produit : Onduleur photovoltaïque injection réseau

Modèle: KF-SPI30K-B, KF-SPI33K-B, KF-SPI36K-B,
KF-SPI40K-B, KF-SPI50K-B, KF-SPI60K-B

Version logiciel : HMI: V2, DSP1: V2, DSP2: V2

**Règles de raccordement
au réseau :** UTE C 15-712-1/07.13
Installations photovoltaïques sans stockage et raccordées au réseau public de
distribution
Enedis-NOI-RES_13E : 2013-06
Protections des installations de production raccordées au réseau public de distribution
DIN VDE V 0126-1-1/08.13
Organe de commutation automatique entre une installation de production
autonome parallèle au réseau et le réseau à basse tension public

Numéro rapport d'essai : 50186674 002

Numéro de certificat : AK 50419826 0001

Date d'émission : 2018.10.09



Li Weichun
General Manager

TÜV Rheinland LGA Products GmbH – Tillystraße 2 – 90431 Nürnberg