



Harmonics Report for SPI125K-B

Total harmonic distortion rate of current report

Harmonics Model: SPI125K-B			
Measurement			
P/P _n [%]	5	50	100
THD	4.37%	2.52%	1.23%
2	0.181	0.184	0.311
3	0.037	0.05	0.07
4	0.117	0.056	0.037
5	0.176	0.199	0.156
6	0.026	0.027	0.028
7	0.156	0.143	0.215
8	0.124	0.046	0.059
9	0.033	0.045	0.057
10	0.09	0.053	0.074
11	0.186	0.208	0.189
12	0.027	0.028	0.028
13	0.161	0.158	0.178
14	0.037	0.029	0.035
15	0.034	0.03	0.046
16	0.034	0.038	0.039
17	0.138	0.086	0.144
18	0.032	0.031	0.033
19	0.159	0.072	0.148
20	0.034	0.032	0.038
21	0.032	0.03	0.048
22	0.031	0.03	0.04
23	0.102	0.083	0.178
24	0.045	0.051	0.052
25	0.082	0.108	0.078
26	0.035	0.034	0.038
27	0.032	0.035	0.046
28	0.043	0.034	0.042
29	0.126	0.122	0.152
30	0.033	0.037	0.039
31	0.041	0.042	0.034
32	0.048	0.047	0.052
33	0.03	0.042	0.052
34	0.043	0.045	0.046
35	0.053	0.068	0.054
36	0.07	0.077	0.093
37	0.076	0.067	0.054
38	0.064	0.081	0.093
39	0.034	0.041	0.048
40	0.043	0.041	0.049



- END -

Kehua Data Co., Ltd.

Add: No. 457, Malong Road, Torch High-Tech Industrial Zone, Xiamen Fujian 361006 China

Tel: +86-592-5160516

Fax: +86-592-5162166

Email: Intertrade@kehua.com

KEHUA France SAS

Add: 3 place du général de Gaulle 13001 Marseille France

Tel: +33 (0)4 65 38 62 48

Email: contact@kehua-france.com